

PUBLIC NOTICE
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Requirements Not Met for the Dora Water System

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Our water system recently violated a drinking water requirement. Although this is not an emergency, as our customers, you have a right to know what happened, what we are doing to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the 2023 to 2025 monitoring period we did not monitor or did not complete all monitoring requirements for lead and copper in tap water and, therefore, cannot be sure of the quality of your drinking water during that time.

What should you do?

There is nothing you need to do at this time.

What happened? What is being done? In 2026, May 19 and October 13, the Village of Dora completed 10 lead and copper samples to determine if our water met health standards for lead and copper. In May, our 90th percentile in lead was 0.0011 and 0.047 for copper. In October, our 90th percentile in lead was ND (not detected) and 0.028 for copper which are both within the parameters for lead and copper.

For more information, please contact:

Becky Frazee at 575-477-2411 or at
Dora Water System, NM3528222
PO Box 308
Dora, NM 88115

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.